



SECTION

ELEVATION

NOTES

- ① SEE DRAWING NO. 4001 FOR REQUIREMENTS WHEN SEWER CONNECTION IS CONSTRUCTED IN THE VICINITY OF A WATER MAIN.
- ② WHERE LATERAL IS CONSTRUCTED UNDER AN EXISTING CURB, THE CONTRACTOR SHALL CHISEL THE LETTER "L" INTO THE CURB FACE DIRECTLY ABOVE THE LATERAL. "L" TO BE 1-1/2" HIGH & 3/16" DEEP.



APPROVED BY: <i>John P. Sullivan</i> 24079 08/15/06				
JOHN P. SULLIVAN CITY ENGINEER RCE DATE				
RECOMMENDED: <i>Scott B. Burton</i> 57875 08/14/06				
ASST. UTIL. DIRECTOR/ENG. RCE DATE				
REV	DESCRIPTION	BY	APP'D	DATE

CITY OF ONTARIO

SEWER CHIMNEY

STANDARD
DRAWING
NUMBER

2004