



#### NOTES:

- ① PAINT INSIDE AND OUTSIDE OF ENCLOSURE WITH PRIMER AND FINISH COAT PER THE MANUFACTURER'S APPLICATION INSTRUCTIONS, 2.5 MILS. MINIMUM EACH.
- ② PAINT COLOR IS DESERT SAND OR BAJA BEIGE.
- ③ LOCATION OF UNIVERSAL AIR RELEASE VALVE ASSEMBLY WILL BE DETERMINED BY THE CITY INSPECTOR AT THE TIME OF INSTALLATION.
- ④ SIZE OF UNIVERSAL AIR RELEASE VALVE ASSEMBLY WILL BE SHOWN ON PLANS.
- ⑤ ALL FITTINGS TO BE THREADED FROM GATE VALVE AT MAIN TO GATE VALVE AT THE AIR RELEASE VALVE.



APPROVED BY: <i>Louis Abi-Younes</i> 11-22-10				
LOUIS ABI-YOUNES, CIV. ENGINEER		44485	RCE	DATE
RECOMMENDED: <i>Scott Burton</i> 10/25/10		57875	RCE	DATE
SCOTT BURTON, UTILITIES ENG./OPERATIONS DIRECTOR				
REV	DESCRIPTION	BY	APP'D	DATE

#### CITY OF ONTARIO

#### 2" AND SMALLER AIR RELEASE AND VACUUM RELIEF VALVE ASSEMBLY

STANDARD  
DRAWING  
NUMBER

**4102**