



NOTES:

- ① FRONT OF METER BOX TO BE LOCATED 6" BEHIND BACK OF WALK FOR SIDEWALK ADJACENT TO CURB AND 6" BACK OF CURB FOR SIDEWALK ADJACENT TO RIGHT OF WAY, UNLESS OTHERWISE SPECIFIED.
- ② RUN SOFT COPPER, TYPE "K", SERVICE TO PROPERTY LINE OR BEYOND AND CAP/MINIMUM 36".
- ③ METER (5/8" X 3/4" OR 1") SHALL BE SUPPLIED BY THE CITY AT CONTRACTOR'S EXPENSE, UNLESS OTHERWISE APPROVED 5/8" AND 3/4" METERS REQUIRE A 1"x3/4" BUSHING.
- ④ ALL FITTINGS TO BE COMPRESSION TYPE, NO FLARED OR SOLDERED FITTINGS SHALL BE USED.
- ⑤ REFER TO STANDARD DRAWING NO. 4001 FOR SEPARATION FROM SEWER LATERALS
- ⑥ LOCATION OF LATERAL PER CITY AND 5' AWAY FROM ALL OBSTRUCTIONS.
- ⑦ 12" BRASS NIPPLE BETWEEN BALL VALVE AND COPPER SERVICE LINE.



APPROVED BY:				
<i>John P. Sullivan</i>				
JOHN P. SULLIVAN CITY ENGINEER		RCE	24079	4/1/5
RECOMMENDED:				
<i>Scott Brubaker</i>				
ASST. UTIL. DIRECTOR/ENG.		RCE	57875	3/14/5
REV	DESCRIPTION	BY	APP'D	DATE

CITY OF ONTARIO

1" WATER SERVICE

STANDARD
DRAWING
NUMBER

4201