


NOTES

- DIAMETER FOR PIPELINE & APPURTENANCES SHALL BE EQUAL TO THE METER SIZE.
- THE WATER SERVICE VAULT SHALL BE LOCATED & INSTALLED SUBJECT TO APPROVAL OF THE CITY.
- ADJUST VAULT & COVER TO MEET SIDEWALK & CURB GRADE.
- ALL METAL INSIDE VAULT TO BE PAINTED WITH PRIMER AND TWO (2) COATS OF PAINT.
- ALL FIELD JOINTS SHALL BE FLANGED UNLESS OTHERWISE INDICATED. ALL WELDED JOINTS ON LINED STD. WT. PIPE SHALL BE SHOP FABRICATED.
- SHOULD THE DEPTH OF THE VAULT EXCEED FOUR (4) FEET, AN OSHA APPROVED LADDER ATTACHED TO AN INSIDE WALL SHALL BE PROVIDED. THE LOCATION OF THE LADDER SHALL BE AS DIRECTED BY THE CITY.
- VAULT DOORS SHALL BE 5'x6'.
- DOOR HINGES SHALL SIT ABOVE THE IN & OUT OF THE METER AND SHALL BE SPRING LOADED.

** 6" AND 8" COMPOUND WATER METER						
METER SIZE	DIMENSION					CONTINUOUS FLOW RANGE GPM
	A	B	C	D	E	
6"	36"	72"	96"	20"	45"	5 to 1000
8"	36"	72"	96"	24"	53"	5 to 2000

- MAINLINE ϕ X BRANCH ϕ (A.W.W.A.) FLANGED OUTLET TEE
- VALVE BOX & GATE VALVE INSTALLATION PER CITY OF ONTARIO STD. DWG. NO. 4005.
- 150# SLIP ON WELD FLANGE (TYPICAL)
- CML&C W.S.P. (10 GA. MIN.)
- CML&C W.S.P. (10 GA. MIN.) A.W.W.A. FLANGED TEE IF REQUIRED BY THE CITY.
- STD. WT. STL. PIPE CML&C
- CML&C A.W.W.A. FLANGED 90° BEND (FLANGED STD. WT. STL. 90° BEND MAY BE SUBSTITUTED UPON APPROVAL BY THE CITY OF ONTARIO.
- KNOCKOUTS AS REQUIRED (2" LARGER THAN PIPE SIZE O.D. ALL AROUND)
- REMOVE AN ADEQUATE AMOUNT OF CMC TO ALLOW PROPER INSTALLATION OF THE FLANGED COUPLING ADAPTOR. PAINT BARE METAL PER NOTE 4.
- COMPOUND MASTER METER OR FIRE SERVICE METER WITH BRONZE BY PASS ASSEMBLY WITH COVER.
- FLANGED COUPLING ADAPTOR.
- 2 1/2" THREADED FIRE PROTECTION GATE VALVE, IPT X NST WITH HOSE CAP. ALL BRONZE W/ IRON HAND WHEEL, 175 PSI MWWP.
- PIPE SUPPORT PER CITY OF ONTARIO STD. DWG. NO. 4307
- PRE-CAST CONCRETE VAULT WITH 2 PIECE 6' X 8' TORSION HINGED ALUMINUM COVER. QUICKSET OR APPROVED EQUAL. COVER TO BE SPECIFIED FOR TRAFFIC LOADS WHERE REQUIRED.



APPROVED BY:		11-22-10	
LOUIS ABI-YOUNES, CITY ENGINEER		44485	
RECOMMENDED:		10/25/10	
SCOTT BURTON, UTILITIES ENG/OPERATIONS DIRECTOR		57875	
REV	DESCRIPTION	BY	APP'D DATE

CITY OF ONTARIO

6" AND 8" WATER
SERVICE METER

STANDARD
DRAWING
NUMBER

4204