



CONCRETE PAD - PLAN VIEW

NOTES:

- ① ALL PIPE AND FITTINGS SHALL BE BRASS.
- ② NO CONNECTION SHALL BE INSTALLED BETWEEN THE METER AND THE BACKFLOW ASSEMBLY.
- ③ ASSEMBLY SHALL BE ON THE LATEST U.S.C. F.C.C.C. & H.R. INSTITUTE LIST AND COMPLY WITH STATE OF CALIFORNIA DEPARTMENT OF PUBLIC HEALTH GUIDELINES.
- ④ BACKFLOW ASSEMBLY SHALL BE INSTALLED AS CLOSE TO THE PROPERTY LINE AS POSSIBLE. LOCATION SHALL BE APPROVED BY THE CITY ENGINEER.
- ⑤ BACKFLOW ASSEMBLY SHALL BE INSTALLED HORIZONTAL AND LEVEL, UNLESS ALTERNATIVE ORIENTATION APPROVED BY U.S.C. F.C.C.C. & H.R. AND THE STATE OF CALIFORNIA DEPARTMENT OF PUBLIC HEALTH.
- ⑥ BACKFLOW ASSEMBLY SHALL BE LOCATED IN DENSE LANDSCAPE AREAS, OR AREAS NOT VISIBLE TO PUBLIC VIEW. LOCATION SHALL BE APPROVED BY THE CITY ENGINEER.
- ⑦ OPTIONAL STRONGBOX VANDAL RESISTANT ENCLOSURE, SIZE AS NECESSARY, PAINT PER SPECIFICATIONS



APPROVED BY:		11-8-11	
LOUIS ABI-YOUNES, CITY ENGINEER		44485	
RECOMMENDED:		10/25/11	
SCOTT BURTON, ASSISTANT UTILITIES GENERAL MANAGER		57875	
REV	DESCRIPTION	BY	APP'D DATE

CITY OF ONTARIO	
BACKFLOW PREVENTION ASSEMBLY 2" & SMALLER - REDUCED PRESSURE DEVICE	
STANDARD DRAWING NUMBER	4206