



DETAIL "A"
NOT TO SCALE

NOTES

1. ROCK SIZES, UNLESS OTHERWISE SPECIFIED, SHALL BE COBBLESTONES, MAX. 12" TO MIN. 6", WITH ONE SIDE FLAT.
2. MINIMUM OF 1/2 OF THE COBBLE THICKNESS SHALL BE EMBEDDED IN 4" PEA GRAVEL CONCRETE BED.
3. ALL SPACES BETWEEN STONES SHALL BE FILLED WITH CLASS "D" MORTAR, 1 PART CEMENT TO 2 1/2 PARTS SAND, 2000 p.s.i. PORTLAND CEMENT CONCRETE. NO DRY PACK IS ALLOWED. FILL TO 2/3 HEIGHT OF ROCK. THE SURROUNDING CURB, SIDEWALK AND ASPHALT PAVEMENT SHALL BE PROTECTED FROM SPILLAGE.
4. A SAMPLE AREA, MIN. 10 SQ. FT., SHALL BE APPROVED BY THE CITY INSPECTOR PRIOR TO PROCEEDING WITH THE REMAINING ROCK WORK.
5. FINAL RESTING POSITION OF ALL ROCKS SHALL BE APPROVED BY THE CITY INSPECTOR.
6. ROCKS SHALL BE SMOOTH, ROUNDED, FREE OF OBJECTIONABLE DISFIGURATIONS AND IRON CONTENT, AS APPROVED BY THE CITY INSPECTOR.
7. CONCRETE SHALL BE CLASS 520-D-2500.
8. AFTER CONCRETE MORTAR HAS SET, HYDRO BLAST OR ACID ETCH, AS DIRECTED BY THE CITY INSPECTOR. BRUSH ROCKS TO REMOVE CEMENT COATING.
9. THE 18" WIDE CONCRETE STRIP IS FOR MEDIANS 8' WIDE AND OVER.



APPROVED BY:				
<i>John P. Sullivan</i>				
JOHN P. SULLIVAN CITY ENGINEER		RCE DATE 8/08/06		
RECOMMENDED:				
<i>Jim Min Mack</i>				
ASSISTANT CITY ENGINEER		RCE DATE 8/07/06		
REV	DESCRIPTION	BY	APP'D	DATE

CITY OF ONTARIO

ROCK MEDIAN

STANDARD
DRAWING
NUMBER

1215