



MANHOLE SHALL BE A PRECAST CONCRETE ECCENTRIC MANHOLE (5 FOOT IN. DIA.) WITH A 36-INCH DIA. OPENING.
 6" PALMER-BOWLUS FLUME INSTALLED PER MANUFACTURER'S RECOMMENDATIONS
 WASTEWATER MONITORING STATION'S MAXIMUM FLOW = 0.2658 MGD
 MANHOLE BASE SHALL BE MONOLITHICALLY POURED.



APPROVED BY:		11-22-10	
<i>Louis Abi-Younes</i>		44485	
LOUIS ABI-YOUNES, CITY ENGINEER		RCE	DATE
RECOMMENDED:		10/25/10	
<i>Scott Burton</i>		57875	
SCOTT BURTON, UTILITIES ENG/OPERATIONS DIRECTOR		RCE	DATE
REV	DESCRIPTION	BY	APP'D DATE

CITY OF ONTARIO

MANHOLE
MONITORING
STATION

STANDARD
DRAWING
NUMBER

2205