



NOTES

- ① 1" DIA. BRONZE CORP. STOP, (MIPT x PE (CPS).
- ② 1" DIA. PE TUBING (SPS) SDR 7 WITH TRACER WIRE
- ③ WATER MAIN SIZE x 1", SERVICE SADDLE
- ④ METER BOX
- ⑤ 1" DIA. BRONZE ANGLE METER STOP, (PE(CPS) x METER COUPLING NUT)
- ⑥ 5/8" OR 1" METER W/RADIOREAD, ACQUIRED THROUGH THE CITY
- ⑦ 3/4" DIA. CRUSHED ROCK BASE OR NATIVE MATERIAL, AS DETERMINED IN THE FIELD BY THE CITY.
- ⑧ LINE SIZE DIA. BALL VALVE
- ⑨ TRACER WIRE TO BE TAPED TO PIPELINE EVERY 10 FT.



APPROVED BY: <i>Louis Abi-Younes</i> 11-22-10				
LOUIS ABI-YOUNES, CITY ENGINEER 44485 RCE DATE				
RECOMMENDED: <i>Scott Burton</i> 10/25/10				
SCOTT BURTON, UTILITIES ENG/OPERATIONS DIRECTOR 57875 RCE DATE				
REV	DESCRIPTION	BY	APP'D	DATE

CITY OF ONTARIO

1" WATER SERVICE
DETAIL (PE TUBING)
(PVC PIPE)

STANDARD
DRAWING
NUMBER

4210