



## NOTES

- ① 2" DIA. BRONZE CORP. STOP, (MIPT x PE (CPS).
- ② 2" DIA. PE TUBING (SPS) SDR 7 WITH TRACER WIRE
- ③ WATER MAIN SIZE x 2", SERVICE SADDLE
- ④ METER BOX
- ⑤ 2" DIA. BRONZE ANGLE METER STOP, (PE(CPS) x METER COUPLING NUT)
- ⑥ 1-1/2" OR 2" METER W/RADIOREAD, ACQUIRED THROUGH THE CITY
- ⑦ 3/4" DIA. CRUSHED ROCK BASE OR NATIVE MATERIAL, AS DETERMINED IN THE FIELD BY THE CITY.
- ⑧ LINE SIZE DIA. BALL VALVE
- ⑨ TRACER WIRE TO BE TAPED TO PIPELINE EVERY 10 FT.



APPROVED BY:		11-22-10	
<i>Louis Abi-Younes</i>		44485	
LOUIS ABI-YOUNES, CITY ENGINEER		RCE	DATE
RECOMMENDED:		10/25/10	
<i>Scott Burton</i>		57875	
SCOTT BURTON, UTILITIES ENG/OPERATIONS DIRECTOR		RCE	DATE
REV	DESCRIPTION	BY	APP'D DATE

CITY OF ONTARIO

2" WATER SERVICE  
DETAIL (PE TUBING)  
(PVC PIPE)

STANDARD  
DRAWING  
NUMBER

4211