


PLAN VIEW

MANHOLE SHALL BE A PRECAST CONCRETE ECCENTRIC MANHOLE (5 FOOT IN. DIA.) WITH A 36-INCH DIA. OPENING. 6" PALMER-BOWLUS FLUME INSTALLED PER MANUFACTURER'S RECOMMENDATIONS WASTEWATER MONITORING STATION'S MAXIMUM FLOW = 0.2658 MGD MANHOLE BASE SHALL BE MONOLITHICALLY POURED.



APPROV	ED BY: 1/	1	*******	11-20	-10
LOUIS AE	G HU	ENGINEER	_	44485 RCE	DATE
RECOM	MENDED:	Burh	4	5787	10
SCOTT BI	JRTON, UTILITIES	ENG/OPERATION	DNS DIRE		
REV	DESCRIF	PTION	BY	APP'D	DATE

CITY OF ONTARIO

MANHOLE MONITORING STATION STANDARD DRAWING NUMBER

2205